

S.No 3

Government of India
Ministry of Railways
Railway Board

No.2002/Elect(G)/148/5.

New Delhi, 9th July, 2002.

M/s. Delhi Metro Rail Corporation Ltd.,
NBCC Place,
Bhishma Pitamah Marg,
Pragati Vihar,
NEW DELHI – 110 003.

(ATTN : SHRI SATISH KUMAR, DIRECTOR (RS,Elect. and S&T – Fax No.4365843) .

Sub : TRACTION SYSTEM FOR UNDERGROUND LINE NO.2 OF DMRC.

- Ref. : 1. DMRC's letter No.DMRC/68/99/Elect/766 dt.17.06.02.
2. DMRC's letter No.DMRC/Elect/68/99/Elect/804 dt.05.07.02
3. ... DMRC's letter No. DMRC/Elect/68/99/Elect. Dt. 9.7.2002.

DMRC's proposal for adoption of 25 kV AC rigid traction system for the underground Line No.2 of Delhi Metro is agreed to in principle subject to strict observance of all international safety standards and clearances as per IEC 913 and EN 50122-1/ACTM inside the tunnel. However, safety provisions of ACTM shall be followed as far as the traction system outside the tunnel is concerned.

The detailed design of the traction system, when finalised, may be sent to Railway Board for examination.

21/5/2002
(ANOOP GUPTA)
Director Elect. Engg. (PS)

Copy to:

- ✓ 1. Exe. Director (TI), RDSO, Manak Nagar, Lucknow.
2. Exe. Director (DMRC), Railway Board, New Delhi.

Mr. K. K. Gupta,