

✓

**GOVERNMENT OF INDIA  
MINISTRY OF RAILWAYS  
(RAILWAY BOARD)**

2012/Proj./Jaipur/30/7(SoD)

New Delhi, dated 06.2013

**Managing Director,  
Jaipur Metro Rail Corporation Ltd.,  
Khanij Bhavan,  
Behind Udyog Bhavan, C-Scheme  
Jaipur- 302005.**

**Sub: Technical Clearance of Jaipur Metro Rail Corporation Ltd.**

The request of Jaipur Metro Rail Corporation Ltd. contained in their letter No.F7(B-17)JMRC/RDSO/2012/12657 dated 28.3.2013 regarding technical clearance of Traction System has been examined in Board's office as well as in RDSO. Based on the scrutiny made by RDSO in this case, 'In-principle approval' of Board on Traction System is hereby conveyed subject to the following observations:-

"Details of Protection scheme, Control and monitoring of Traction and Auxiliary power system for Jaipur Metro, Phase-I have been submitted by JMRCL, which is already under implementation. There is no possibility of up-gradation in Phase-I. However, for Phase-II (Sitapura-Aruvavadi Section), JMRCL has assured to implement the upgraded protection scheme conforming to RDSO Spec. No. TI/SPC/PSI/PROTCT/4050".

JMRCL to incorporate the corrections suggested by RDSO in various OHE drawings and submit it to RDSO for permanent record.

8/0

*Avinash*  
18/6/13  
(Avinash)

**Deputy Director/Project  
Railway Board**

Copy to: Executive Director/UTHS,RDSO, Manak Nagar, Lucknow.

*PT. Doss*  
18/6/13

