

Government of India
Ministry of Railways
(Railway Board)

No. 2004/Sig/W/5

Dated 27.05.2019

The Principal CSTE
West Central Railway
Jabalpur.

Sub: - Provision of Automatic Fire Detection and Alarm System

Ref: - Railway Board's Letter No. 2015/Sig/A/Fire/Pt. dated 8.11.2016 (Copy Enclosed)

Vide Railway Board's Letter under reference, it has been directed that

- (a) Automatic Fire Detection and Alarm System shall be provided at all the stations irrespective of routes.
 - (b) Automatic Fire Suppression System along with Automatic Fire Detection and Alarm System shall be provided with more than 400 routes.
2. While carrying out review of provision of Automatic Fire Detection and Alarm Systems at Signaling Installations on your Railway, the following position has been noted:-

Railway (1)	Total No. of Stations (2)	As on 31.03.2019 (3)	% Provided (4)
WCR	279	103	37 %

3. There have been serious cases of fire in Signaling Installations and as such it is of utmost importance to provide Automatic Fire Detection & Alarm Systems in Signaling Installations on highest priority.
4. You are requested to kindly advise what target has been set by you for completing provision of Fire Detection & Alarm Systems at all the balance Signaling Installation on your Railway.

Encl. as above


(Rajeev Sharma)
Additional Member (Signal)

भारत सरकार) GOVERNMENT OF INDIA
(रेल मंत्रालय) MINISTRY OF RAILWAYS
(रेलवे बोर्ड) RAILWAY BOARD

No. 2015/Sig/A/Fire/Pt

New Delhi, dt 08.11.2016

Chief Signal & Telecom Engineers,
All Indian Railways.

CORE/ALC

Sub: Prevention of fire hazards in S&T Buildings.

Ref: - Board's letter No. 2015/Sig/84th SSC dated 16.08.2016.

Reference above, Board has approved the recommendation of 84th SSC w.r.t item No. 1183 as under:-

1. 'Automatic fire Detection and Alarm System' shall be provided at all the station irrespective of number of routes.
2. 'Automatic Fire Suppression System' along with 'Automatic Fire Detection and Alarm System' shall be provided at stations with more than 400 routes.
3. For less than 400 routes, provision of 'Automatic Fire Suppression System' along with 'Automatic Fire Detection and Alarm System' may be considered by Zonal Railways at critical stations and important junctions, with the approval of General Manager.

This is for urgent necessary action to avoid fire hazards in S&T Buildings.

Ed
8/11/16

Harsh Deep Srivastava
(Director (Signal))